

# VOC Content Test Certificate

Monday 24<sup>th</sup> April 2023

Supplier: CSR Building Products Ltd (Trinita 3, Level 5, 39 Delhi Road North Ryde NSW 2113, Australia)

Sample Description: Gyprock® Ultra-Base MR 60

Date Tested: April 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960: Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

<b>Specification</b> <b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3-13.1.1B</b> <b>Green Star Interiors V1.3-12.1.1B</b>	<b>Gyprock® Ultra-Base MR 60</b>
<b>General Purpose Adhesives and Sealants Limit:</b> <b>50 grams per litre</b>	<b>2 grams per litre as VOC content per material</b>
<b>Meets GBCA VOC Content Requirement</b>	<b>Yes</b>
<p><i>The results above may be considered representative of the equivalent and lesser weighted product specifications that are made from the same raw material by CSR Building Products and these include Gyprock® Cornice Cement 45, Gyprock® Cornice Cement 60, Gyprock® Cornice Cement 90, Gyprock® Base Coat 20, Gyprock® Base Coat 45, Gyprock® Base Coat 60, Gyprock® Base Coat 90, Gyprock® Pro-Repair 10, Gyprock® Plaster Accelerator, Gyprock® Drywall Masonry Adhesive, Gyprock® Back Blocking Cement, Gyprock® Casting Plaster, Gyprock® Pottery Plaster, Gyprock® Dental Plaster, Gyprock® Superfine Plaster, Gyprock® Hardwall Plaster, Gyprock® Cornice Cement, Gyprock® Rapid Patch, Gyprock® Perforated Filler, Gyprock® Rapid Set, and Gyprock® Masonry Adhesive.</i></p>	



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant



Dr. Tuan Duong  
 PhD, BE (Chem. Eng.)  
 Senior Consultant



Travis Hale  
 BSc (Biotechnology)  
 Senior Consultant

Issue date: 24/04/2023

Expiry date: 24/04/2028

P23030017