

Emission Test Certificate

Thursday 13th July 2023

Supplier: CSR Interior Systems (376 Victoria Street, Wetherill Park, NSW 2164, Australia)

Sample Description: Gyprock EC08™ Extreme Plasterboard

Date Tested: September 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

<p>Green Building Council of Australia Green Star Design & As Built V1.3 - 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p>Gyprock EC08™ Extreme</p>
<p>Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.025 mg/m²/hr</p>
<p>Formaldehyde emission Rate Limit: ≤0.100 mg/m²/hr</p>	<p>Formaldehyde emission Rate: 0.021 mg/m²/hr</p>
<p><i>The results above may be considered representative of the equivalent and lesser weighted product specifications that are made from the same raw material by CSR Building Products and these include Gyprock Impactchek™.</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Consultant



Dr. Tuan Duong
PhD, B.Eng. (Chemical)
Senior Consultant

Issued date: 3/10/2022

Expiry date: 3/10/2027

P22080147_Ver1